

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Staff of New C.R. Sr. Sec. School

(Name of Officers with designation) from District Water Testing Lab Hisar PHED

inspected the NEW C.R. School, Ublana

(Name & Address of the school) on 19/02/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 312 dated 20/02/2026

of District Water Testing Lab Hisar (PHED Lab) certified that the

New C.R. School, Ublana (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 Months

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: PHED



Department, Hisar

To The Principal,
New C.R. School, Ublana
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,HISAR

PHED
Haryana

Website :- <https://phedharyana.gov.in/>

Memo No:- 312

Date:- 20/02/2026

Subject : Physical / Chemical Examination Report of Water Sample

HC-1012

Sample ID/Classification : HSR/08361/2/2026 / Private		Sample Details	Date & Time
Sender :	New CR School Uklana	Collected By	ASHISH KUMAR
Location :	, NEW CR SR SEC SCHOOL	Collection Date	19/02/2026 at 12:17
Sample Description :	Drinking Water	Received at lab	19/02/2026 at 15:17
Latitude / Longitude :	75.897064 / 29.493764	Analysis Start Date	19/02/2026
		Analysis End Date	20/02/2026
		Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.52	1 NTU	5 NTU	APHA 24th Edition -2130 B : 2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B : 2023
5	Total Dissolved Solids @ 180°C ± 2°C	156	500 mg/lt.	2000 mg/lt.	APHA 24th Edition -2540 C : 2023
6	Total Hardness as CaCo3	78.8	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2340 C : 2023
7	Calcium as Ca	18.59	75 mg/lt.	200 mg/lt.	APHA 24th Edition-3500-Ca B : 2023
8	Magnesium as Mg	7.87	30 mg/lt.	100 mg/lt.	APHA 24th Edition -3500 Mg B : 2023
9	Total Alkalinity	52.4	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2320 B : 2023
10	Chloride as Cl	51.04	250 mg/lt.	1000 mg/lt.	APHA 24th Edition -4500 Cl-B : 2023
11	Sulphate as So4	38	200 mg/lt.	400 mg/lt.	APHA 24th -4500 SO4-E : 2023
12	Fluoride as F	0.274	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C : 2023
13	Iron as Fe	0.01	1.0 mg/lt.	1.0 mg/lt.	USEPA 45(126-43459) : 2018
14	Nitrate as No3	0.8	45 mg/lt.	45 mg/lt.	APHA 24th Edition -4500 NO3 D : 2023
15	pH @ 25°C	6.79	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B : 2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :


KANCHAN BISHNOI, CHEMIST
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in



PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,HISAR

Website :- <https://phedharyana.gov.in/>

Subject : **Bacteriological Examination Report of Water Samples**

Circle Hisar Circle

Division Hisar PHED No. 2

Sub Division Barwala PHESD

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
Memo No :- 315, Date :- 23/02/2026				
1	Sample ID:-HSR/08359/2/2026 /Sender : NEW CR SR SEC SCHOOL ,Location : , NEW CR SR SEC SCHOOL, Analysis Start/End Date: 19/02/2026 / 23/02/2026, GPS Coordinates: 76.432081 /29.059006			
	Total Coliform per 100 ml	0	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023	Potable
Abstract Report of Bacteriological Examination Report of Water Sample				
Total Sample		Potable		Not Potable
1		1		0

L96
No.
8488

* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

- * The Results Given above are related to the sample as received and tested in HISAR lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.

KANCHAN BISHNOI,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,HISAR
email:-chemist.hisar@phedharyana.gov.in

Sample analyzed by :